

OG-100 ICC-SRCC™ CERTIFIED SOLAR AIR HEATING COLLECTOR # 2011124A

SUPPLIER: Matrix Energy 294 Labrosse Avenue Pointe Claire, Québec Canada H9R 5L8 matrixairheating.com BRAND: MatrixAir MODEL: TR

COLLECTOR TYPE: Air Transpired
CERTIFICATION NUMBER: 2011124A
ORIGINAL CERTIFICATION DATE: May 31, 2019

Certifications are subject to annual renewal

The solar collector listed below has been evaluated by the Solar Rating & Certification CorporationTM (ICC-SRCCTM), an ISO 17065 accredited Certification Body, in accordance with ICC-SRCC OG-100, Operating Guidelines and Minimum Standards for Certifying Solar Collectors, and has been certified by ICC-SRCC. This award of certification is subject to all terms and conditions of the OG-100 Program Agreement and the documents incorporated therein by reference. This document must be reproduced in its entirety.

OG-100 COLLECTOR EFFICIENCY RATINGS¹ (η) – Black Absorber Color²						
Wind Speed³ ►	Low Wind	Medium Wind	High Wind			
Air Flow Rate	(1.0 m/s, 2.2 mph)	(2.0 m/s, 4.5 mph)	(3.0 m/s, 6.7 mph)			
0.9 scmm/m ² (3.0 scfm/ft ²)	0.43	0.36	0.27			
1.5 scmm/m ² (5.0 scfm/ft ²)	0.57	0.49	0.40			
2.1 scmm/m ² (6.7 scfm/ft ²)	0.60	0.53	0.46			


^{1:} Thermal efficiency (η) is based on aperture area and does not include back losses.


3. Efficiency data adjusted to 1.0, 2.0, 3.0 m/s speeds by means of linear interpolation. Original data available in Testing Summary below.

CERTIFIED COLLECTOR SPECIFICATIONS

Collectors must match the design of the sample tested for certification. In order to be considered certified, installed collectors must match the following specifications.

Туре	□ Unglazed			
	☐ Glazed			
Description	1-Stage Open-Loop Transpired Solar Air Heating Collector			
Max. Flow Rate	2.1 scmm/m ² (6.7 scfm/ft ²)*			
Panel Width	900 mm (35.4 in)*			
Panel Length	Varies			
Air Inlet	Transpired – Absorber perforations			
Air Outlet	Variable			
Installation Orientation	0° (horizontal) - 90° (vertical)			
ABSORBER				
Туре	Painted perforated plate			
Material	Steel plate, 24 gauge*			





^{2:} Efficiency ratings are based on test data for the specific collector described in the "Collector Test Sample Details" section below. Performance values for collectors that use an absorber painted a different color than the one tested can be estimated by multiplying the efficiency values above by the ratio of the absorptivity of the new paint color and the absorptivity of the tested collector (0.94 in this case). This assumes that the new color paint has a similar emissivity to the tested collector (0.88 in this case), the absorbers in each stage are the same color. Absorptivity should be measured per ASTM C1549.




TESTING SUMMARY MATRIXAIR TR COLLECTOR ICC-SRCC OG-100 CERTIFICATION #2011124A

Test Lab
Test Report Number
Test Report Date
Test Standard

Bodycote Testing 06-08-9157-A May 15, 2007 CSA F378-1987 Laboratory testing of a collector sample is required for OG-100 certification to confirm that the collector passes qualification tests and to obtain performance results. The following sections provide information on the collector tested for the purposes of OG-100 certification.

COLLECTOR TEST SAMPLE DETAILS					
Absorber	Coating	Paint: Black, 6068			
	Absorptivity	0.94**			
	Material	Steel			
	Porosity	1.6%			
	Profile	35150			
Gross Area		4.720 m ² (50.8 ft ²)			
Aperture Area (Net)		4.720 m ² (50.8 ft ²)			
Gross Sample		2.465 m x 1.915 m x 19.05 - 22.86 cm			
Dimensions (LXWXH)		8.087 ft x 6.283 ft x 9.0 - 7.5 in			
		(Depth varied from 9.0" at bottom to			
		7.5" at top)			
Dry Weight		Not Reported			
THERMAL EFFICIENCY TESTING DETAILS					
Testing Location		Indoors, conditioned space (25°C)			
Added Back Insulation		2" rigid foam			



THERMAL EFFICIENCY DATA SUMMARY (908 W/m ² average insolation)									
	Wind Speed	0.0 m/s (0.0 mph)		1.3 m/s (2.9 mph)		2.2 m/s (4.9 mph)		3.3 m/s (7.4 mph)	
Air Flow		η	Δ T (K)***						
0.9 scmm/m ²	(3.0 scfm/ft ²)	0.50	23.6	0.41	19.1	0.34	15.6	0.27	12.4
1.5 scmm/m ²	(5.0 scfm/ft ²)	0.62	0.48	0.55	15.6	0.47	13.3	0.40	11.3
2.1 scmm/m ²	(6.7 scfm/ft ²)	0.64	0.60	0.59	13.0	0.51	11.4	0.46	10.1

^{**} Data measured by test lab at the time of collector testing per CSA F378.

REMARKS:

- 1. Performance is unreliable if the collector is used at a pressure drop of less than 25 Pa.
- 2. Wind impact on efficiency should not be extrapolated to large-scale systems because the ratio of wind-blown edge loss to gain across the surface area is diminished for large vs. small collectors (arrays).
- 3. All lengths of this collector are certified.



Vice President of Technical Services, ICC-SRCC



^{***} T defined as T_e-T_a where T_e is the temperature of the air exiting the collector and T_a is the ambient (inlet) air temperature.